

*The A55 Trunk Road (Abergwyngregyn, Gwynedd)  
(Clearway) Order 1994*

Notice is hereby given that on 1st December 1994, the Secretary of State made the above Order which will come into operation on 5th December 1994.

The effect is as stated in Notice 488 in *The London Gazette* No. 53812 dated 7th October 1994.

A copy of the Order and plan may be inspected during normal office hours at the offices of Arfon Borough Council, Legal Services, Town Hall, Bangor, Gwynedd, during a period of 6 weeks from 5th December 1994. (482)

*The A55 Trunk Road (Abergwyngregyn, Gwynedd)  
(Restricted Roads) Order 1994*

Notice is hereby given that on 1st December 1994, the Secretary of State made the above Order which will come into operation on 5th December 1994.

The effect is as stated in Notice 481 in *The London Gazette* No. 53825 dated Thursday, 27th October 1994.

A copy of the Order and plan may be inspected during normal office hours at the offices of Arfon Borough Council, Town Hall, Bangor, Gwynedd, during a period of 6 weeks from 5th December 1994. (483)

## DEPARTMENT OF THE ENVIRONMENT

### WATER INDUSTRY ACT 1991: SECTION 19(1)(b)

The purpose of this notice is to inform consumers in parts of Llangynydd Village near Maesteg who might be affected by improvement work being carried out by Dŵr Cymru Cyfyngedig at its Llangynydd Service Reservoir. The Company has found through its water quality monitoring programme that water supplied from this reservoir has on occasion not met the standard, as required by the Water Supply (Water Quality) Regulations 1989, for total and faecal coliforms, although the water has at all times been, and remains safe to drink. Consequently the Secretary of State for Wales has notified the Company that he will carry out his duty under section 19 of the Water Industry Act 1991 and if necessary, order the Company to take appropriate steps to ensure that the water supplied will in future meet the required standard for total and faecal coliforms.

The Company gave a legally binding agreement (called an undertaking) to carry out appropriate remedial work at Llangynydd Service Reservoir to be completed by 31st March 1994. The Secretary of State satisfied that the Company was complying with this agreement informed the Company that he was satisfied by serving on them the notice printed below.

#### WATER INDUSTRY ACT 1991: SECTION 19(1)(b)

The Secretary of State for Wales:

1. is satisfied that Dŵr Cymru Cyfyngedig "the Company" when supplying water from its Llangynydd Service Reservoir has contravened and is likely to do so again its duty to supply wholesome water under section 68(1)(a) of the Water Industry Act 1991, and the requirement of Regulation 3(7) of the Water Supply (Water Quality) Regulations 1989, that water supplied should not contain total and faecal coliforms.
2. has notified Dŵr Cymru Cyfyngedig on 19th August 1993 that he is considering making in relation to the Company an enforcement order under section 18 of the Water Industry Act 1991.
3. notes that Dŵr Cymru Cyfyngedig has on 20th December 1993 given an undertaking under section 19(1)(b) of the Water Industry Act 1991 to take the following steps by the dates shown:—
  - (a) Carry out regular inspections at a frequency of 3 per week of residual chlorine levels and maintain at a target residual chlorine value of 0.1mg/l. To continue for the duration of the undertaking.
  - (b) Carry out a structural survey of the reservoir. To be completed by 28th February 1994.
  - (c) Offer a further undertaking in respect of any repairs found necessary by the structural survey. To be completed by 31st March 1994.
  - (d) Install and optimise booster chlorination at the inlet to Llangenor Service Reservoir. To be completed by 31st March 1994.

(e) If coliform organisms detected in any sample, follow instructions given in sections 7.7 to 7.11 of "Guidance on Safeguarding the Quality of Public Water Supplies" as appropriate. To be completed as soon as analytical results become available and not more than 30 hours after the time of sampling.

4. is satisfied that Dŵr Cymru Cyfyngedig has given and is complying with an undertaking to take all such steps as appear to the Secretary of State for the time being to be appropriate to secure or facilitate compliance with the requirement of Regulation 3(7) of the Water Supply (Water Quality) Regulations 1989.

Details of the work carried out are on the Company's public record which you may inspect at any of its offices open to the public during normal working hours.

You can find out about the work in this undertaking which has now been completed, and whether your water supply is affected by telephoning the Water Company on 0874-623181, or writing to them at Plas-y-Ffynnon, Cambrian Way, Brecon, Powys LD3 7HP; and quoting DoE undertaking reference number DC 019.

A copy of the undertaking can also be seen at the offices of the Director General of Water Services, City Centre Tower, 7 Hill Street, Birmingham B5 4UA. (Ref. No. LG1/01/DWI).

M. Rouse, Chief Inspector Authorised by the Secretary of State to sign in that behalf.

21st November 1994.

(2SI)

### WATER INDUSTRY ACT 1991: SECTION 19(1)(b)

The purpose of this notice is to inform consumers in parts of Church Village, Tonyrefail, the Upper Rhymney Valley and the Sirhowy Valley who might be affected by improvement work being carried out by Dŵr Cymru Cyfyngedig at its Pontsticill Water Treatment Works. The Company has found through its water quality monitoring programme that water supplied from this works has on occasion not met the standard, as required by the Water Supply (Water Quality) Regulations 1989, for trihalomethanes, although the water has at all times been, and remains safe to drink. Consequently the Secretary of State for Wales has notified the Company that he will carry out his duty under section 19 of the Water Industry Act 1991 and if necessary, order the Company to take appropriate steps to ensure that the water supplied will in future meet the required standard for trihalomethanes.

The Company gave a legally binding agreement (called an undertaking) to carry out appropriate remedial work at Pontsticill Water Treatment Works to be completed by 31st December 1994. The Secretary of State satisfied that the Company was complying with this agreement informed the Company that he was satisfied by serving on them the notice printed below.

#### WATER INDUSTRY ACT 1991: SECTION 19(1)(b)

The Secretary of State for Wales:

1. is satisfied that Dŵr Cymru Cyfyngedig "the Company" when supplying water from its Pontsticill Water Treatment Works has contravened and is likely to do so again its duty to supply wholesome water under section 68(1)(a) of the Water Industry Act 1991, and the requirement of Regulation 3(3)(e) of the Water Supply (Water Quality) Regulations 1989, that samples taken from water supplied to the water supply zone in question have established that the average concentrations over the three preceding months of trihalomethanes (being the aggregate of the concentrations of trichloromethane, dichlorobromomethane, dibromochloromethane and tribromomethane) did not exceed 100mg/l, or where (by virtue of regulation 13(3) less than four samples are taken in any year, no sample contained a concentration of trihalomethanes in excess of 100mg/l.
2. has notified Dŵr Cymru Cyfyngedig on 19th August 1993 that he is considering making in relation to the Company an enforcement order under section 18 of the Water Industry Act 1991.
3. notes that Dŵr Cymru Cyfyngedig has on 20th December 1993 given an undertaking under section 19(1)(b) of the Water Industry Act 1991 to take the following steps by the dates shown:—
  - (a) Complete rebuilding of water treatment works to include provision of DAF units and two-stage rapid gravity filtration. Intermediate stages and target dates: Commence commissioning—30th August 1994. Complete commissioning and takeover—31st December 1994.